

G-254

High Rise Hose Bundle

G-254.1 PURPOSE & SCOPE

The purpose of this guideline is to provide a standard High Rise hose bundle for fire suppression operations at high-rise or apartment emergency incidents.

G-254.2 GUIDELINE

It is the guideline of the San Mateo County Fire Chiefs that all fire companies maintain at least one approved high rise hose bundle described below as part of their standard hose complement.

G-254.3 REFERENCES

N/A

G-254.4 PROCEDURES

1. The standard high rise hose pack shall include:
 - a. 100 feet of 1 ½ or 1 ¾ inch hose with 1½ inch NST threads
 - b. 1 Combination/Extendable Nozzle with 1 ½ NST threads
 - c. 6 to 10 feet of 2 ½ inch hose with 2 ½ inch NST threads
 - d. 1 gated wye 2 ½ to 1 ½ inch with NST threads