

# San Mateo County Fire Service POLICIES AND STANDARDS MANUAL

Title: High Rise Hose Bundle

Policy No. 2000-03

Adopted 08/01/00

Revised xx/xx/xx

**Purpose:** The purpose of this policy is to provide a standard High Rise hose bundle for fire suppression operations at high-rise or apartment emergency incidents.

**Policy:** It is the policy of the San Mateo County Fire Chiefs that all fire companies maintain at least one approved high rise hose bundle described below as part of their standard hose complement.

**Background:**

**Standard:**

1. The standard high rise hose pack shall include:
  - 100 feet of 1 ½ or 1 ¾ inch hose with 1½ inch NST threads
  - 1 Combination/Extendable Nozzle with 1 ½ NST threads
  - 6 to 10 feet of 2 ½ inch hose with 2 ½ inch NST threads
  - 1 gated wye 2 ½ to 1 ½ inch with NST threads